



GERT SIBANDE DISTRICT MUNICIPALITY

WATER QUALITY LABORATORY

Enquiries : Victoria Tshabalala
E-mail : Laboratoryservices@gsibande.gov.za
Int. Ref : LDP0010/2025
Ext. Ref : 2025/10/28 (240279 & 240280)

26 November 2025

Attention: Mr. Shabangu
Dipaleseng Local Municipality
Private Bag X1005
Balfour

EXTERNAL REPORT COMMENT EX AQUATICO LAB : LDP0010/2025.

The determinands tested on potable water samples for the above mentioned report meet the requirements of the south African Drinking Water Standard, SANS241-1 :2015

p.p. @k.

Manager: Microbiology

Yours Sincerely

VM. Tshabalala

HEAD OF SCIENTIFIC SERVICES

Certificate of Analysis 20251104-P643-P647

Client name: Aquatico Scientific Pty Ltd
Telephone number: 012 450 3800
Email Address: Outsource@aquatico.co.za
Address: 89 Regency Drive, Route 21 Corporate Park
Irene Ext. 72, Centurion, 0178

Sampling date: 28-Oct-2025
Sampling site: N/A
Sampling point: N/A
Sample receipt date: 04 November 2025
Test completion date: 13 November 2025
Report date: 13 November 2025

Sample Description:	Water Sample
Condition of samples upon receipt:	Acceptable
Test Method:	TM-07 Cryptosporidium and Giardia Screening using real-time PCR

Analytical Results

Laboratory Sample Number	Client Sample Ref	PO Number	Volume analysed	Test Result
20251104-P643	372866 Balfour - Fortuna WTW Final	AQS 2025 908	10 L	Cryptosporidium not detected Giardia not detected
20251104-P644	372867 Siyathemba 24 Charls Street	AQS 2025 908	10 L	Cryptosporidium not detected Giardia not detected
20251104-P645	372868 Siyathemba Reservoir	AQS 2025 908	10 L	Cryptosporidium not detected Giardia not detected
20251104-P646	372869 Nthorwana Reservoirs	AQS 2025 908	10 L	Cryptosporidium not detected Giardia not detected
20251104-P647	372870 Grootvlei Clinic	AQS 2025 908	10 L	Cryptosporidium not detected Giardia not detected

Comments:

These results relate only to the items tested and to the sample as received from the customer.


This test report shall not be reproduced except in full, without the written approval of SpesLab.

Information related to the test samples, as supplied by the customer, can affect the validity of results.

Technical Signatory: Nicole Kennedy



---End of Report---



Suite 200, P/Bag X025
Lynnwood Ridge, 0040
South Africa

115 Excelsior str
Meyerspark
Pretoria
South Africa

Gerrit: 082 5781152
Tel: (012) 803 6046
International: (27 12) 803 6046
Fax: (086) 6807256
e-mail: gerrit@aquadoc.co.za
VAT Nr. 42 601 581 02

Date: 10/11/2025

JT: 16469

REPORT ON WATER ANALYSIS

Submitter: AQUATICO SCIENTIFIC PTY LTD
Address: P O Box 905008, Garsfontein, Pretoria, 0042
Tel: (012) 450 3800
Fax: (012) 450 3851
Attention: Anri Joubert
Email: anri@aquatigo.co.za

Sample description: 6 x Somatic coliphage

Vat nr: 4170261228

Date received: 04/11/2025

Date completed: 10/11/2025
Order No: AQS 2025 907

Sample	Somatic coliphage / 10ml
372861 Balfour - Fortuna WTW Final	0
372862 Siyathemba 24 Charls Sreet	0
372863 Siyathemba Reservoir	0
372864 Nthorwana Reservoir	0
32865 Grootvlei Clinic	0

This report relates only to the samples as actually received by AQUADOC Analytics cc. This Company does not accept responsibility for any matters arising from the further use of these results.

Gerrit Idema